



ČOV: **Pavlovice** Průtok celkem: 11241
 m3/rok
 Název firmy: Obec Pavlovice
 Adresa: Pavlovice 18, 25801 Vlašim Čistící efekt:
 Kontaktní osoba: Daněk dle BSK5 99,1 %
 Telefon: dle NL 97,3 %
 dle N-NH4 99,1 %
 dle Pc 89,2 %
 dle P_{tot} 79,3 %

ČOV	Obec Pavlovice, Pavlovice, 258 01 Vlašim											
Průtok	pH	BSK ₅ [mg/l]	CHSK ₅ [mg/l]	NL [mg/l]	RAS [mg/l]	N-NO ₂ [mg/l]	N-NO ₃ [mg/l]	N-NH ₄ [mg/l]	N _{tot} [mg/l]	N _{amonn} [mg/l]	N _{oh} [mg/l]	P _{tot} [mg/l]
27.01.2020	8,30	424,6	705	264			105,10					19,60
24.02.2020	8,80	578,8	903	568			123,70					19,50
23.03.2020	8,30	570,5	1032	348			92,40					17,10
20.04.2020	8,60	1208,5	1762	1448			113,30					23,50
25.05.2020	8,90	357,9	648	256			136,50					19,50
22.06.2020	8,20	176,3	342	196			48,60					9,59
27.07.2020	7,20	400,0	798	106			18,80					26,00
24.08.2020	8,00	542,4	1628	1096			100,30					24,50
21.09.2020	8,50	383,5	646	960			176,70					22,10
26.10.2020	8,70	578,5	1369	260			106,30					16,80
23.11.2020	7,50	904,4	1725	800			127,30					21,50
21.12.2020	8,90	1050,6	1734	832			112,50					11,20
Průměr	8,33	598,0	1108	595			105,13					19,24

ČOV	Obec Pavlovice, Pavlovice, 258 01 Vlašim												
Odtok	pH	BSK ₅ [mg/l]	CHSK ₅ [mg/l]	NL [mg/l]	RAS [mg/l]	N-NO ₂ [mg/l]	N-NO ₃ [mg/l]	N-NH ₄ [mg/l]	Aktivaec [g/l]	Inhoff [ml/l]	Ncelk [mg/l]	Pcelk [mg/l]	Tuky [mg/l]
Limity	6 - 9	40	120	40				20					
27.01.2020	6,5	21,4	117	25			15,00	3,47	320,00				7,50
24.02.2020	7,0	5,5	67	41			19,70	4,57	460,00				8,74
23.03.2020	7,5	15,6	89	24			17,10	4,22	420,00				5,73
20.04.2020	7,2	3,9	101	12			18,70	3,40	800,00				7,52
25.05.2020	7,5	25,9	120	19			19,20	2,94	180,00				8,96
22.06.2020	6,9	3,4	48	10			0,81	3,39	360,00				2,79
27.07.2020	6,7	4,0	85	16			4,48	3,74	850,00				7,30
24.08.2020	7,1	11,4	97	22			18,70	4,15	810,00				8,63
21.09.2020	7,3	14,4	90	23			19,10	4,08	950,00				7,40
26.10.2020	7,2	9,1	79	16			19,40	4,73	950,00				9,34
23.11.2020	7,0	4,2	66	15			17,80	3,77	700,00				7,43
21.12.2020	7,0	15,0	116	25			5,00	3,81	920,00				7,30
Průměr	7,1	11,2	89,6	17,6			14,58	3,85	643,33				7,39

prekročen limit "p"

prekročen limit "n"

sledovaná hodnota